

§ 200.952

100. The label shall include the manufacturer's name and plant location.

(c) *Periodic tests and quality assurance inspection.* Under the procedure set forth in §200.935(d)(8), testing and inspection shall be conducted as follows:

(1) The Administrator shall visit the manufacturer's factory every two years to assure that the initially accepted quality assurance procedures are being followed.

(2) At least every four years, the administrator shall visit the manufacturer's facility to select a sample of each certified solar water heating system for testing by a laboratory approved by the administrator.

(d) *Warranty.* The manufacturer shall provide, at no cost, a full five-year warranty against defects in material or workmanship, on the absorber plate, cooling passages, and the collector (excluding any glass), running from the date of installation of the solar water heating system. The warranty also shall include the full costs of field inspection, parts, and labor required to remedy the defects, and will include the cost of replacement at the site if required. This warranty is not required to cover defects resulting from exposure to harmful materials, fire, flood, lightning, hurricane, tornado, hailstorms, earthquakes, or other acts of God, vandalism, explosions, harmful chemicals or other fluids, fumes or vapors. This exclusion will apply to the operation of the collector under excessive pressures or excessive flow rates, misuse, abuse, negligence, accidents, alterations, falling objects or other causes beyond the control of the manufacturer. Following the initial five years, the manufacturer shall provide a limited no-cost five-year warranty for collector parts on a prorata allowance basis.

[58 FR 67676, Dec. 22, 1993]

§ 200.952 Supplementary specific requirements under the HUD building product standards and certification program for particleboard interior stair treads.

(a) *Applicable standards.* (1) All interior particleboard stair treads shall be designed, manufactured, and tested in compliance with ANSI A208.1-1993 Particleboard, Grade M-3.

24 CFR Ch. II (4-1-03 Edition)

(2) This standard has been approved by the Director of the Federal Register for incorporation by reference in accordance with 5 U.S.C. 552(a) and 1 CFR part 51, and is available from the American National Standards Institute, Inc., 11 West 42nd Street, New York, NY 10036.

(b) *Labeling.* Under the procedures set forth in §200.935(d)(6) concerning labeling of a product, the administrator's validation mark and the manufacturer's certification of compliance with the applicable standard are required to be on the certification label issued by the administrator to the manufacturer. Each interior particleboard stair tread shall include the manufacturer's statement of conformance to UM 70b, a statement that this product is for interior use only, and the manufacturer's name and plant location.

(c) *Periodic tests and quality assurance.* Under the procedures set forth in §200.935(d)(8) concerning periodic tests and quality assurance inspections, the frequency of testing for a product shall be described in the specific building product certification program. In the case of interior particleboard stair treads, testing and inspection shall be conducted as follows:

(1) At least once every three months, the administrator shall visit the manufacturer's facility to select a sample for testing in a laboratory approved by the administrator.

(2) The administrator shall also review the quality assurance procedures twice a year to assure that they are being followed by the manufacturer.

[63 FR 5424, Feb. 2, 1998]

§ 200.954 Supplementary specific requirements under the HUD building product standard and certification program for construction adhesives for wood floor systems.

(a) *Applicable standards.* (1) All construction adhesives for field glued wood floor systems shall be designed, manufactured, and tested in compliance with the following American Society for Testing and Materials (ASTM) standard: D 3498-93 Standard Specification for Adhesives for Field-Gluing Plywood to Lumber Framing for Floor Systems except that the mold and bacteria resistance tests shall not be included.